



Date: June 11, 2004

Subject: Inclusion of UL Classified Speaker Assembly in UL Fire Rated Acoustical Ceiling Designs

Underwriters Laboratories Inc. has completed revisions to BPB floor-ceiling and roof-ceiling fire rated acoustical ceiling designs to include a UL Classified Speaker Assembly. The following item has been added to UL Designs D203, D205, G208, G218, G255, L201, P204, P259, P260, P261, P262 and P264. This speaker assembly was already included in UL Designs G222 and G259.

Speaker Assemblies* — (Not Shown) Optional. The speaker assemblies consist of speakers, speaker enclosures and their accessories. The ceiling penetration for the speaker enclosure shall not exceed 11-7/8 by 11-7/8 in. for the square speaker enclosures and 12 in. in diam for the round speaker enclosures. The speaker assemblies are installed in accordance with the installation instructions provided. A maximum of two 144 sq in. speaker assemblies per 100 sq ft of ceiling area is allowed.

ATLAS SOUND L P

See **Speaker Assemblies For Fire Resistance (CHML)**, Atlas/Sound L P for specific Types.

*Bearing the UL Classification Mark

Please contact the Technical Services Department if there are any questions regarding this update.

Marketing Technical Services Department



BPB America Inc.
5301 W. Cypress Street, Ste. 300, Tampa, Florida 33607-1176 USA
www.bpb-na.com
Toll Free: +1 866 4BPB USA (1-866-427-2872)
Fax: +1 813 286 3991
Email: crc@bpb-na.com